



Inspection Report

Inspection Date: 2026/07/01

Generator

General Information

Maker	DENYO
Model Number	DCA-60SPH
Year	1999
Hour (h)	8239
Serial Number	3699949

Note for External Appearance

- GENERATOR
- 60kVA
- Normal working condition

Engine

Model	W06E-H
Serial Number	W06E H14056
Engine Oil Leak	Oil oozing
Engine Oil Gauge	OK
Exhaust Color	Normal
Blow-by	No
Engine Sound	OK
Radiator	OK
Water Pump	No water leak
Injection Pump	No fuel leak

Note for Control Panel

Note for Engine

Admin. No. 3000087817

*This report is only for your reference. We are not responsible for the actual condition of checked item.