



# Inspection Report

Inspection Date: 2018/07/23

## Generator

### General Information

<b>Maker</b>	AIRMAN
<b>Model Number</b>	SDG100S
<b>Year</b>	2002
<b>Hour (h)</b>	4606
<b>Serial Number</b>	1533A10715

### Note for External Appearance

### Engine

<b>Model</b>	A-6BG1 TQD
<b>Serial Number</b>	
<b>Engine Oil Leak</b>	No oil leak
<b>Engine Oil Gauge</b>	OK
<b>Exhaust Color</b>	Normal
<b>Blow-by</b>	No
<b>Engine Sound</b>	OK
<b>Radiator</b>	OK
<b>Water Pump</b>	No water leak
<b>Injection Pump</b>	No fuel leak

### Note for Control Panel

### Note for Engine

Admin. No. 2018070806

\*This report is only for your reference. We are not responsible for the actual condition of checked item.