



# Inspection Report

Inspection Date: 2026/09/19

## Generator

### General Information

|               |               |
|---------------|---------------|
| Maker         | SHINDAIWA     |
| Model Number  | DG450UMI-Q    |
| Year          | 0             |
| Hour (h)      | 3352          |
| Serial Number | 21444-0000258 |

### Note for External Appearance

- Repainted

### Engine

|                  |               |
|------------------|---------------|
| Model            |               |
| Serial Number    |               |
| Engine Oil Leak  | No oil leak   |
| Engine Oil Gauge | OK            |
| Exhaust Color    | Normal        |
| Blow-by          | No            |
| Engine Sound     | OK            |
| Radiator         | OK            |
| Water Pump       | No water leak |
| Injection Pump   | No fuel leak  |

### Note for Control Panel

### Note for Engine

Admin. No. 3000089655

\*This report is only for your reference. We are not responsible for the actual condition of checked item.